


Diana L. Quast, Town Clerk  
dquast@yorktownny.org



**Registrar of Vital Statistics**  
Telephone: (914) 962-5722 x 208  
Fax: (914) 962 6591

**TOWN OF YORKTOWN**  
363 Underhill Avenue, P.O. Box 703  
Yorktown Heights, NY 10598

October 3, 2016

Dear Bidder:

Re: Bid for Preventative Maintenance and On-call Services of Emergency Generators

A representative of Genserveinc.com has sent an email to my office requesting answers to the following questions. The answers were supplied by Michael Quinn, the Town Engineer.

- 1) Page #35 #5 Some of the generators are older and some of the replacement parts may not be available from local suppliers and may only be able to be ordered from the factory.

Answer: Point noted and acknowledged

- 2) Page #35 #6 If a software issue is found to be a problem and the OEM needs to be involved due to licensing of software the Contractor should be expected to absorb this cost.

Answer: If the Contractor submits an extra cost proposal that includes an outside vendor, it will be reviewed and may be approved as an extra work item as described in the contract terms and conditions.

- 3) In the Scope of Work does the Automatic Transfer Switch Maintenance need to be done at the time of the Major PM or can it be done at the time of the Minor Service.

Answer: Can be done at either time.

Cordially,

Diana L. Quast  
Town Clerk  
Town of Yorktown