

FARMWALK PUMP STATION DATA SHEET

PUMP STATION LOCATION: Section 06.02 Block 18 Lot 2.56

Address/nearest street or intersection: Farmwalk Road

COUNTY SEWER DISTRICT: Peekskill LOCAL SEWER DISTRICT: Osceola

SERVICE AREA: Approximately 80 residential parcels

NAME OF RECEIVING TREATMENT WORKS: Westchester County Peekskill
Wastewater Treatment Plant

NAME OF WATERSHED AREA IN WHICH PUMP STATION IS LOCATED: Croton

DATE OF ORIGINAL CONSTRUCTION OF PUMP STATION: 1991

DESIGN CAPACITY: 80 gpm

NUMBER OF PUMPS: 2

PUMP RATED CAPACITY (EACH): 80 gpm

FORCE MAIN SIZE: 3-inch

RECEIVING MANHOLE LOCATION: Farmwalk Road

DESCRIBE EMERGENCY POWER/GENERATOR INFORMATION: Onsite generator

DESCRIBE ALARM SYSTEM AND CONTACT SEQUENCE: Verbatim and telephone alarm system. Initial call goes to plant operator then to remaining sewer department personnel until alarm acknowledgment occurs.

ARE THERE ANY OVERFLOW OR BYPASS PIPES? No

ARE THERE WATERBODIES LOCATED NEAR THE PUMP STATION? No

DATES OF MAJOR RECONSTRUCTION/CAPITAL IMPROVEMENTS: None

DESCRIBED WORK PERFORMED: NA

INSPECTION/MAINTENANCE FREQUENCY FOR PUMP STATION: Semi-Weekly

CRYSTAL LAKE PUMP STATION DATA SHEET

PUMP STATION LOCATION: Section 10.20 Block 4 Lot 77

Address/nearest street or intersection: Granite Springs Road

COUNTY SEWER DISTRICT: None LOCAL SEWER DISTRICT: Hallock's Mill

SERVICE AREA: Approximately 35 residential parcels

NAME OF RECEIVING TREATMENT WORKS: Yorktown Heights Water Pollution Control Facility

NAME OF WATERSHED AREA IN WHICH PUMP STATION IS LOCATED: Croton

DATE OF ORIGINAL CONSTRUCTION OF PUMP STATION: 1981

DESIGN CAPACITY: 30 gpm

NUMBER OF PUMPS: 2

PUMP RATED CAPACITY (EACH): 30 gpm

FORCE MAIN SIZE: 4-inch

RECEIVING MANHOLE LOCATION: Granite Springs Road

DESCRIBE EMERGENCY POWER/GENERATOR INFORMATION: Onsite generator

DESCRIBE ALARM SYSTEM AND CONTACT SEQUENCE: Telephone alarm system. Initial call goes to plant operator then to remaining sewer department personnel until alarm acknowledgment occurs.

ARE THERE ANY OVERFLOW OR BYPASS PIPES? No

ARE THERE WATERBODIES LOCATED NEAR THE PUMP STATION? Yes

NAME OF WATERBODY: Crystal Lake

DATES OF MAJOR RECONSTRUCTION/CAPITAL IMPROVEMENTS: None

DESCRIBED WORK PERFORMED: NA

INSPECTION/MAINTENANCE FREQUENCY FOR PUMP STATION: Daily (Monday – Friday)

HANOVER EAST PUMP STATION DATA SHEET

PUMP STATION LOCATION: Section 15.19 Block 6.1 Lot .005

Address/nearest street or intersection: Wellington Way and Kensington Lane

COUNTY SEWER DISTRICT: None LOCAL SEWER DISTRICT: Hallock's Mill

SERVICE AREA: Approximately 60 residential parcels

NAME OF RECEIVING TREATMENT WORKS: Yorktown Heights Water Pollution Control Facility

NAME OF WATERSHED AREA IN WHICH PUMP STATION IS LOCATED: Croton

DATE OF ORIGINAL CONSTRUCTION OF PUMP STATION: 1989

DESIGN CAPACITY: 100 gpm

NUMBER OF PUMPS: 2

PUMP RATED CAPACITY (EACH): 100 gpm

FORCE MAIN SIZE: 4-inch

RECEIVING MANHOLE LOCATION: Wellington Court

DESCRIBE EMERGENCY POWER/GENERATOR INFORMATION: Onsite generator

DESCRIBE ALARM SYSTEM AND CONTACT SEQUENCE: Auto telephone alarm system. Initial call goes to plant operator then to remaining sewer department personnel until alarm acknowledgment occurs.

ARE THERE ANY OVERFLOW OR BYPASS PIPES? No

ARE THERE WATERBODIES LOCATED NEAR THE PUMP STATION? No

DATES OF MAJOR RECONSTRUCTION/CAPITAL IMPROVEMENTS: None

DESCRIBED WORK PERFORMED: NA

INSPECTION/MAINTENANCE FREQUENCY FOR PUMP STATION: Daily (Monday-Friday)

MOHANSIC PUMP STATION DATA SHEET

PUMP STATION LOCATION: Section 04.13 Block 63 Lot 18

Address/nearest street or intersection: Loretta Street and Route 202

COUNTY SEWER DISTRICT: None LOCAL SEWER DISTRICT: Hallock's Mill

SERVICE AREA: Approximately 90 residential parcels

NAME OF RECEIVING TREATMENT WORKS: Yorktown Heights Water Pollution Control Facility

NAME OF WATERSHED AREA IN WHICH PUMP STATION IS LOCATED: Croton

DATE OF ORIGINAL CONSTRUCTION OF PUMP STATION: 1959

DESIGN CAPACITY: 90 gpm

NUMBER OF PUMPS: 2

PUMP RATED CAPACITY (EACH): 90 gpm

FORCE MAIN SIZE: 6-inch

RECEIVING MANHOLE LOCATION: Route 202

DESCRIBE EMERGENCY POWER/GENERATOR INFORMATION: Onsite generator

DESCRIBE ALARM SYSTEM AND CONTACT SEQUENCE: Verbatim and telephone alarm system. Initial call goes to plant operator then to remaining sewer department personnel until alarm acknowledgment occurs.

ARE THERE ANY OVERFLOW OR BYPASS PIPES? No

DATES OF MAJOR RECONSTRUCTION/CAPITAL IMPROVEMENTS: None

DESCRIBED WORK PERFORMED: NA

OVERFLOW/BYPASS HISTORY DURING THE PAST YEAR: NA

INSPECTION/MAINTENANCE FREQUENCY FOR PUMP STATION: Semi-Weekly

SALEM PUMP STATION DATA SHEET

PUMP STATION LOCATION: Section 04.19 Block 48 Lot 2.1

Address/nearest street or intersection: Salem Road

COUNTY SEWER DISTRICT: None LOCAL SEWER DISTRICT: Hallock's Mill

SERVICE AREA: Approximately 30 residential parcels

NAME OF RECEIVING TREATMENT WORKS: Yorktown Heights Water Pollution Control Facility

NAME OF WATERSHED AREA IN WHICH PUMP STATION IS LOCATED: Croton

DATE OF ORIGINAL CONSTRUCTION OF PUMP STATION: 1979

DESIGN CAPACITY: 30 gpm (est.)

NUMBER OF PUMPS: 2

PUMP RATED CAPACITY (EACH): 30 gpm (est.)

FORCE MAIN SIZE: 4-inch

RECEIVING MANHOLE LOCATION: Salem Road

DESCRIBE EMERGENCY POWER/GENERATOR INFORMATION: Onsite generator

DESCRIBE ALARM SYSTEM AND CONTACT SEQUENCE: Auto telephone alarm system. Initial call goes to plant operator then to remaining sewer department personnel until alarm acknowledgment occurs.

ARE THERE ANY OVERFLOW OR BYPASS PIPES? No

ARE THERE WATERBODIES LOCATED NEAR THE PUMP STATION? No

DATES OF MAJOR RECONSTRUCTION/CAPITAL IMPROVEMENTS: None

DESCRIBED WORK PERFORMED: NA

INSPECTION/MAINTENANCE FREQUENCY FOR PUMP STATION: Daily (Monday – Friday)